

PROJECT NUMBER: 3018 02 0173-4

PAGE: 1 OF 2

DATE: OCTOBER 7, 2002

SOUND ABSORPTION TEST

ASTM C423-99a

INTRODUCTION:

This report presents the results of a Sound Absorption test conducted on PVC Baffles manufactured by All Noise Control. This test was requested by All Noise Control on August 1, 2002 with the testing completed on September 26, 2002.

This report must not be reproduced except in its entirety with the approval of Stork / Twin City Testing Corporation. The data in this report relates only to the items tested.

Stork / Twin City Testing Corporation has been accredited by the U.S. Department of Commerce and the National Institute of Standards and Technology (KIST, formerly IBS) under their National Voluntary Laboratory Accreditation Program (NVL,AP) for conducting this test procedure. This report may not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

SUMMARY OF RESULTS:

When tested using the Type I mounting, the test samples obtained the following absorption values: (expressed in Sabins/Baffle)

SPECIMEN DESCRIPTION

The specimen was manufactured and identified by All Noise Control as white, 3 MIL PVC encapsulated baffles with thick 1.6-2.0 PCF fiberglass core. The dimensions of the specimens were 24"x48" x 1 weighing 2.7-lbs each or 0.34 PSF.

1/3 Oct. Band Hz	Absorption per Baffle
	(Sabins/Baffle)
100	4.04
125	1.74
160	2.63
200	4.15
250	6.13
315	7.44
400	9.00
500	10.39
630	12.03
800	12.13
1000	11.63
1250	10.21
1600	8.19
2000	6.32
2500	5.60
3150	5.01
4000	4.48
5000	4.36

PROJECT NUMBER: 3018 02 0173-4

PAGE: 2 OF 2

DATE: OCTOBER 7, 2002

SOUND ABSORPTION TEST

ASTM C423-99a

INTRODUCTION:

This report presents the results of a Sound Absorption test conducted on PVC Baffles manufactured by All Noise Control. This test was requested by All Noise Control on August 1, 2002 with the testing completed on September 26, 2002.

TEST METHOD:

ASTM: C423-99a, "Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method" was followed in every respect. Four baffles were hung on two suspended cables-4' apart, two baffles per cable, spaced 24" apart. The baffles were 44.5" above the reverberation chamber floor (Type I mounting).

Absorption coefficients are the fraction of diffuse incident sound absorbed by the specimen and are expressed in Sabins per square foot for an extended plane surface or Sabins/Unit for individually suspended items,

The temperature and relative humidity of the chamber during the testing was 23, 0 C and 60%, respectively.

TEST EQUIPMENT:

Manufacturer	Model	Serial #	Description
Norwegian Electronics	NE830	11511	Real Time Spectrum Analyzer
Bruel & Kjaer	3923	815424	Rotating Microphone Boom
Larson-Davis	2560	1032	Pressure Condenser Microphone
Compaq Computer	V20 CIO	A942CZGZE580	Custom Designed Software